

# CERTIFICATE

## CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° pw701\_2018

According to reports N° A18.01147.01, dated on 9/04/2018, we confirm that the below mentioned item was tested at CENTEXBEL with reference to EN-ISO 11952-2: Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test.

The items shows

'EU fire classification E'

Provided that it is properly applied.


The evaluation of this properties is based on evaluation scheme specified in EN 13501-1:2007 +A1:2009 : Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests.

**SAMPLE** Beelite 2D and 3D

**Company** **BEELITE nv**  
Avenue A. Franck 5  
7700 Mouscron  
Belgium

Certificate No. pw701\_2018 is valid until 8/04/2023

Centexbel | Technopark 7 | BE 9052 Gent | Belgium, 9/04/2018

  
Inge De Witte, PhD  
Certification Manager